

## **Model 705**

#### **Dual Check Valve**

### **Application**

Ideal for use where Lead-Free\* valves are required. Designed for installation on potable water lines to protect against both backsiphonage and back pressure of polluted water into the potable water supply. The Model 705 shall provide protection where a potential health hazard does not exist. Applications include indoor and outdoor meter box installations as primary domestic water protection. Standard lay length allows for retrofit of existing dual checks. Lead-free body and checks ensure safe drinking water while providing maximum corrosion resistance.



- ASSE® Listed 1024 (horizontal & vertical flow-up)
- CSA® Certified (horizontal & vertical flow-up)
- NSF® Listed Standard 61, Annex G\*
- Certified to NSF/ANSI 372\* by IAPMO R&T \*(0.25% MAX. WEIGHTED AVERAGE LEAD CONTENT)



Reinforced Nylon (FDA approved) Main valve body

Check modules Delrin ®, NSF Listed

Elastomers Buna Nitrile (FDA approved) **Springs** Stainless steel, 300 series

#### **Features**

Sizes: 3/4", 1"

175 PSI Maximum working water pressure Maximum working water temperature 180°F Threaded connections ANSI B1.20.1

Copper connections **ANSI B16.22** 









#### **Options**

(Suffixes can be combined)


- F with FNPT (female) threaded union inlet connection (standard)
- with FC (female) copper sweat union inlet connection
- FM with FMTC (female) meter thread union inlet connection
- M with MNPT (male) threaded union inlet connection


#### **Accessories**

- Repair kit (RK-705)
- Thermal expansion tank (Model XT)

## Dimensions & Weights (do not include pkg.)

	SIZE		DIMENSION (approximate)				WEIGHT	
ı			A		В		WEIGHT	
	in	mm	in.	mm	in.	mm	lbs.	kg
	3/4	20	4 1/2	114	2 3/16	56	1	0.5
ĺ	1	25	4 1/2	114	2 3/16	56	1	0.5






Zurn Industries, LLC | Wilkins

1747 Commerce Way, Paso Robles, CA U.S.A. 93446 Ph. 855-663-9876, Fax 805-238-5766 In Canada | Zurn Industries Limited

3544 Nashua Drive, Mississauga, Ontario L4V 1L2 Ph. 905-405-8272, Fax 905-405-1292

Rev. B Date: 9/13 Document No. BF-705 Product No. Model 705

#### MODEL 705, 3/4" & 1" (STANDARD & METRIC)



#### **TYPICAL INSTALLATION**

Local codes shall govern installation requirements. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code. Unless otherwise specified, the Model 705 shall be mounted with sufficient side clearance for maintenance.

Capacity thru Schedule 40 Pipe					
Pipe size	5 ft/sec	7.5 ft/sec	10 ft/sec	15 ft/sec	
1/8"	1	1	2	3	
1/4"	2	2	3	5	
3/8"	3	4	6	9	
1/2"	5	7	9	14	
3/4"	8	12	17	25	
1"	13	20	27	40	
1 1/4"	23	35	47	70	
1 1/2"	32	48	63	95	
2"	52	78	105	167	

# **Model 705 • Connections Legend**

U = Indicates location of "union" connection

FNPT = Female National Pipe Tapered Thread MNPT = Male National Pipe Tapered Thread FC = Female Copper Sweat

FMTC = Female Meter Thread Connection (National


Hose Straight Thread)


## **Configurations**

### ALL CONFIGURATIONS ARE REVERSIBLE

FEMALE UNION INLET X FEMALE OUTLET					
INLET (UNION)	OUTLET	PART NUMBER			
3/4" FNPT	3/4" FNPT	34UFX34F-705			
3/4" FMTC	3/4" FNPT	34UFMX34F-705			
1" FNPT	1"FNPT	1UFX1F-705			
1" FNPT	3/4" FNPT	1UFX34F-705			
1" FMTC	1"FNPT	1UFMX1F-705			
1" FMTC	3/4" FNPT	1UFMX34F-705			

FEMALE UNION "COPPER SWEAT" INLET X FEMALE OUTLET					
INLET (UNION)	OUTLET	PART NUMBER			
3/4" FC	3/4" FNPT	34UFCX34F-705			
3/4" FC	1" FNPT	34UFCX1F-705			
1" FC	1" FNPT	1UFCX1F-705			
1" FC	3/4" FNPT	1UFCX34F-705			
MALE UNION INLET X FEMALE OUTLET					
1" MNPT	1" FNPT	1UMX1F-705			





#### **Specifications**

The Dual Check Valve Backflow Preventer shall be certified to NSF/ANSI 372, ASSE® 1024 Listed, CSA B64.6 Listed. The main body shall be Nylon® and utilize a union female inlet thread connection. The Dual Check Valve Backflow Preventer shall be a ZURN WILKINS Model 705.